

# Design Considerations for Environmental Engineering Concrete Structures

Reported by ACI Committee 350

Charles S. Hanskat  
Chair

Lawrence M. Tabat  
Secretary

James P. Archibald\*

William Irwin§

Jerry Parnes

Jon B. Ardahl†

Keith W. Jacobson

Andrew R. Philip§

John W. Baker

Dov Kaminetzky

Narayan M. Prachand

Walter N. Bennett‡

M. Reza Kianoush

Satish K. Sachdev‡

Steven R. Close

David G. Kittridge

William C. Schnobrich

Anthony L. Felder

Dennis C. Kohl

John F. Seidensticker

Carl A. Gentry§

Nicholas A. Legatos

William C. Sherman§

Clifford Gordon||

Larry G. Mrazek

Lawrence J. Valentine

Paul Hedli

Javeed A. Munshi

Miroslav Vejvoda

Jerry A. Holland

Paul Zoltanetzky, Jr.

\*Committee Secretary while this document was being prepared.

†Committee Chair while this document was being prepared.

‡Co-chair of subcommittee that prepared this document.

§Members of subcommittee that prepared this document.

||Deceased.

*Environmental engineering concrete structures provide conveyance, storage, and treatment of water, wastewater, and other materials. This report outlines special design considerations such as loads, stability, joint details, and special design conditions that are unique to these types of structures as well as ancillary structures.*

**Keywords:** buoyancy; clarifier; contraction; design; expansion; filler; flood; flotation; forces; hazardous; ice; impact; joint; load; overturning;

reservoir; safety; sealant; sliding; stability; tank; tension; torque; vibration; waterstop; weights.

## TABLE OF CONTENTS

### Chapter 1—General, p. 350.4R-2

1.1—Scope

1.2—Related documents

### Chapter 2—Design loads, p. 350.4R-2

2.1—Floor live loads

2.2—Contained fluid and sludge loads

2.3—External earth loads

2.4—External fluid loads

2.5—Environmental loads

2.6—Other design loads

### Chapter 3—Stability considerations, p. 350.4R-6

3.1—Flood considerations

3.2—Sliding and overturning considerations

### Chapter 4—Special design conditions, p. 350.4R-9

4.1—Load combinations

4.2—Expansion and contraction conditions

4.3—Foundation conditions

ACI Committee Reports, Guides, Standard Practices, and Commentaries are intended for guidance in planning, designing, executing, and inspecting construction. This document is intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. The American Concrete Institute disclaims any and all responsibility for the stated principles. The Institute shall not be liable for any loss or damage arising therefrom.

Reference to this document shall not be made in contract documents. If items found in this document are desired by the Architect/Engineer to be a part of the contract documents, they shall be restated in mandatory language for incorporation by the Architect/Engineer.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

ACI 350.4R-04 became effective February 27, 2004.

Copyright © 2004, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

This is a preview. Click here to purchase the full publication.

- 4.4—Design and detailing considerations
- 4.5—Vibration conditions
- 4.6—Hazardous design conditions
- 4.7—Corrosive conditions
- 4.8—Construction conditions

## Chapter 5—Joints in concrete, p. 350.4R-13

- 5.1—General
- 5.2—Construction joints
- 5.3—Movement joints
- 5.4—Waterstops
- 5.5—Joint fillers
- 5.6—Joint sealants

## Chapter 6—References, p. 350.4R-15

- 6.1—Referenced standards and reports
- 6.2—Cited references

### CHAPTER 1—GENERAL

#### 1.1—Scope

This report outlines design considerations that are unique to environmental engineering concrete structures and associated buildings. Environmental engineering concrete structures are defined in ACI 350 as concrete structures intended for conveying, storing, or treating water, wastewater, or other nonhazardous liquids, and for the secondary containment of hazardous liquids. Applicable building codes and other industry standards should be consulted for load and design considerations not included herein. The engineer should check with the local building department to confirm the applicable building code for the project location and determine if there are any local amendments.

The structural design recommendations given herein should be regarded as common industry practice and are recommended for general use. Any special structural features, unusual loading conditions, or unusual exposure conditions may require special design considerations to achieve a higher level of performance than implied by these minimum recommendations.

#### 1.2—Related documents

Environmental engineering concrete structures should be designed and constructed in conformance with ACI 350/350R, 350.1, 350.2R, and 350.3. **References 1 through 3** may also be useful in the design of liquid-containing structures.

### CHAPTER 2—DESIGN LOADS

#### 2.1—Floor live loads

Floor live loads in equipment and process areas generally take into account fixed equipment weights, stored material loads, and normal live loads due to personnel and transient loads. Floor live loads should account for installation, operation, and maintenance of equipment, and possible modifications or changes in use.

During installation or maintenance, portions of equipment may be laid down at various locations on the floor. For example, heavy electrical equipment may be temporarily placed near the center span of a floor during installation or maintenance, even though its final location may be near support locations. Weights of concrete bases for equipment may also be

included in floor live loads, and consideration should be given to weights of piping, valves, and other equipment accessories that may be supported by the floor slab. Consequently, conservative uniform live loads are recommended.

Information on estimated equipment weights and footprints should be obtained so that design floor live loads can be verified. The engineer may consider distribution of the equipment loads over an area greater than the footprint dimensions using engineering judgment. Because actual equipment weights from various equipment suppliers may vary, conservative estimates of equipment weights should be used. A minimum floor live load of 150 lb/ft<sup>2</sup> (7.2 kPa) is commonly used for slabs that support equipment. Heavier live loads are common in electrical equipment rooms. Generally, stairways and walkways should be designed for a minimum live load of 100 lb/ft<sup>2</sup> (4.8 kPa). Where loads on catwalks are expected to be limited, a minimum live load of 40 lb/ft<sup>2</sup> (1.9 kPa) may be used in accordance with ASCE 7.

Large pieces of equipment may be assembled in their final fixed location. While temporary laydown of individual pieces of equipment should still be considered, it may be permissible to consider the total weight of the equipment only in its fixed location on the floor. Additionally, operational loads should be considered with the equipment in its fixed location. Operational loads may include thrusts, torques, contained fluids or sludge, or impact. For example, supports for vertical turbine pumps should include the weight of the vertical column of water in the riser, and sludge press loads should include the weight of the sludge being processed in the press.

In areas where chemicals or other materials are stored, the maximum weight of stored material should be determined based on the height and density or specific gravity of the material and its container(s). The material densities listed in **Table 2.1(a) and (b)** may be used for estimating applicable loads. ASCE 7 may be referenced for other common material densities and floor live loads. Chemicals can be delivered and stored by a variety of methods and mediums, including bags, barrels, bottles, cylinders, drums, kegs, pails, rail cars, sacks, totes, or trucks. The engineer should confirm the delivery method and storage method for design.

Caution should be used in applying floor live load reductions as permitted by building codes, due to the greater likelihood of simultaneous distributed loading in some equipment and chemical storage areas. Consider the potential change of use of adjacent areas when setting the floor live load. It is preferable to use the same design live load in adjacent areas where practical. Floor live loads should be posted as indicated in the applicable building code and should be identified on the design drawings.

#### 2.2—Contained fluid and sludge loads

The principal applied loads on liquid-containment structures are due to the fluid pressures on the walls and slabs caused by the contained fluids. The following densities are conservative values for calculating equivalent fluid pressures of common environmental materials encountered that may be used in structural design:

- Raw sewage 63 lb/ft<sup>3</sup> (1000 kg/m<sup>3</sup>)

- Grit excavated from grit chamber 110 lb/ft<sup>3</sup> (1800 kg/m<sup>3</sup>)
- Digested sludge, aerobic 65 lb/ft<sup>3</sup> (1000 kg/m<sup>3</sup>)
- Digested sludge, anaerobic 70 lb/ft<sup>3</sup> (1100 kg/m<sup>3</sup>)
- Thickened or dewatered sludge 63 to 85 lb/ft<sup>3</sup> (1000 to 1400 kg/m<sup>3</sup>)  
(depending on moisture content)

Fluid loads should be considered for both the normal fluid levels and for the worst-case fluid level. One such worst-case

design condition is where the fluid is at the top of the containment structure or at the level at which overflow would occur elsewhere in the hydraulic system, such that high fluid levels could not occur at the location being evaluated. Many liquid-containment structures have encountered such overflow conditions in the past. The code-required load factors and environmental durability factors apply to normal maximum fluid levels. Code-required

**Table 2.1(a)—Densities in inch-pound units of chemical for structural design (refer to Reference 4 for listing of selected chemicals)**

Chemical	Density, lb/ft <sup>3</sup>	Chemical	Density, lb/ft <sup>3</sup>
Acetic acid	65 (liquid)	Fluosillicic acid	79 (liquid at 30%)
Activated carbon	Powder 8 to 28; average 12	Hydrochloric acid	73 (liquid at 35%)
Activated silica	Approximately 90 (liquid)	Hydrofluoric acid	73 (liquid at 55%)
Alum, liquid	83 (liquid at 60 °F)	Hydrogen peroxide	75 (liquid at 50%)
Aluminum ammonia sulfate	70 (granular or powder)	Methanol	98 (liquid)
Aluminum chloride solution	72 (liquid)	Oxygen	71 (liquid)
Aluminum potassium sulfate	70 (granular or powder)	Phosphoric acid	98 (liquid at 75%)
Aluminum sulfate	60 to 75 (granular, powder); 84 (liquid at 50%)	Polyaluminum chloride	91 (liquid at 5%)
Ammonia, anhydrous	43 (liquid at -28 °F)	Polyelectrolyte or polymer	Dry 88; liquid 62 to 92
Ammonia, aqua (ammonium hydroxide)	56 (liquid at 60 °F)	Polyphosphate (zinc orthophosphate)	80 to 100 (liquid)
Ammonia silicoflouride	80 (crystals)	Potassium aluminum sulfate	67 (crystals)
Ammonium aluminum sulfate (ammonium alum)	75 (crystals)	Potassium permanganate	102 (powder); 64 (3% solution)
Ammonium sulfate	60 (damp); 49 to 64 (dry) (crystals)	Sodium aluminate	High-purity 50; standard 60 (powder, crystals); 98 (45% solution)
Barium carbonate	52 to 78 (powder)	Sodium bicarbonate	62 (granular, powder)
Bentonite	Powder 45 to 60; granules 75	Sodium bisulfate	70 to 85 (powder, crystals)
Bromine	194 (liquid)	Sodium carbonate (soda ash)	Dense 65; medium 40; light 30 (granular, powder)
Calcium carbonate	Powder 35 to 60; granules 115	Sodium chloride	Rock 60; crystal 78; powder 66
Calcium hydroxide (hydrated lime)	20 to 50 (powder)	Sodium chlorite	80 (25% solution)
Calcium hypochlorite	Granules 80; powder 32 to 52	Sodium fluoride	Powder 65 to 100; granules crystal 106
Calcium oxide (quick lime, pebble lime)	55 to 70; 60 typical hopper load (pebbles)	Sodium fluorosilicate	72 (powder)
Carbonic acid (carbon dioxide solution)	62 (liquid)	Sodium hexametaphosphate (sodium polysulfate)	Glass 64 to 100; powder and granular 44 to 60
Chlorinated lime	50 (powder)	Sodium hydroxide	Pellets 70; flakes 46 to 62; 95 (50% solution)
Chlorine	92 (liquid)	Sodium hypochlorite	76 (liquid at 15%)
Citric acid	77 (liquid at 50%)	Sodium silicate	88 (liquid)
Copper sulfate	Crystal 90; powder 68	Sodium silicoflouride	Granular 85 to 105; powder-granular 60 to 96
Diatomaceous earth	Natural 5 to 18; calcined 6 to 13; flux-calcined 10 to 25 (fibrous material)	Sodium sulfate	70 to 100 (crystals, powder)
Disodium phosphate	Crystal hydrate 90; anhydrous 64	Sodium sulfite	Powder 80; granular 107; liquid 82 (at 12.5%)
Dolomitic hydrated lime	30 to 50 (powder)	Sodium thiosulfate	60 (granules, crystals)
Dolomitic lime	Pebble 65; ground or lump 50 to 65; powder 37 to 65; average 60	Sulfur dioxide	89.6 at 32 °F (liquid)
Ferric chloride	93 (liquid); crystal 64; anhydrous 45 to 60	Sulfuric acid	115 (liquid)
Ferric sulfate	72 (granular)	Tetrasodium pyrophosphate	Crystal 50 to 70; powder 46 to 68
Ferrous chloride	86 (liquid at 35%)	Trisodium phosphate	Crystal 60; monohydrate 65; anhydrous 70
Ferrous sulfate	66 (granular, powder)		