

Guide for Seismic Rehabilitation of Existing Concrete Frame Buildings and Commentary

Reported by ACI Committee 369



American Concrete Institute®



First Printing
February 2011

American Concrete Institute®
Advancing concrete knowledge

Guide for Seismic Rehabilitation of Existing Concrete Frame Buildings and Commentary

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI. Proper use of this document includes periodically checking for errata at **www.concrete.org/committees/errata.asp** for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Order information: ACI documents are available in print, by download, on CD-ROM, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised *ACI Manual of Concrete Practice* (MCP).

American Concrete Institute
38800 Country Club Drive
Farmington Hills, MI 48331
U.S.A.

Phone: 248-848-3700
Fax: 248-848-3701

www.concrete.org

This is a preview. [Click here to purchase the full publication.](#)

Guide for Seismic Rehabilitation of Existing Concrete Frame Buildings and Commentary

Reported by ACI Committee 369

Kenneth J. Elwood
Chair

Sergio F. Breña*
Secretary

| | | | |
|-----------------------|----------------------------|---------------------|--------------------|
| Sergio M. Alcocer | Shyh-Jiann Hwang | Laura N. Lowes* | Mario E. Rodriguez |
| Jeffrey J. Dragovich* | Mohammad Iqbal | Kenneth A. Luttrell | Murat Saatcioglu |
| Mohammad R. Ehsani | José Izquierdo-Encarnación | Adolfo B. Matamoros | Halil Sezen* |
| Sigmund A. Freeman | Afshar Jalalian | Andrew D. Mitchell | Roberto Stark |
| Wassim M. Ghannoum* | Thomas H.-K. Kang | Jack P. Moehle | Michael T. Valley |
| Zareh B. Gregorian | Dominic J. Kelly | Mark A. Moore | Jacqueline Vinkler |
| Charles J. Hookham | Andres Lepage | Jose A. Pincheira | John W. Wallace |

*Task Group leaders.

This guide, which was developed based on the format and content of ASCE/SEI 41-06, Chapter 6.0, "Concrete," describes methods for estimating the seismic performance of both existing and new concrete components in an existing building. The guide is intended to be used with the analysis procedures and Rehabilitation Objectives established in ASCE/SEI 41-06 for the Systematic Rehabilitation Method. The guide provides recommendations for modeling parameters and acceptance criteria for linear and nonlinear analysis of beams, columns, joints, and slab-column connections of concrete buildings and the procedures for obtaining material properties necessary for seismic rehabilitation design.

Keywords: acceptance criteria; ASCE/SEI 41; beams; columns; frames; joints; modeling parameters; retrofit; seismic rehabilitation; slab-column connections.

CONTENTS

Chapter 1—Introduction and scope, p. 2

- 1.1—Introduction
- 1.2—Scope

Chapter 2—Material properties and condition assessment, p. 3

- 2.1—General

ACI Committee Reports, Guides, Manuals, and Commentaries are intended for guidance in planning, designing, executing, and inspecting construction. This document is intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. The American Concrete Institute disclaims any and all responsibility for the stated principles. The Institute shall not be liable for any loss or damage arising therefrom.

Reference to this document shall not be made in contract documents. If items found in this document are desired by the Architect/Engineer to be a part of the contract documents, they shall be restated in mandatory language for incorporation by the Architect/Engineer.

- 2.2—Properties of in-place materials and components
- 2.3—Condition assessment
- 2.4—Knowledge factor

Chapter 3—General assumptions and requirements, p. 9

- 3.1—Modeling and design
- 3.2—Strength and deformability
- 3.3—Flexure and axial loads
- 3.4—Shear and torsion
- 3.5—Development and splices of reinforcement
- 3.6—Connections to existing concrete
- 3.7—Rehabilitation: general requirements

Chapter 4—Concrete moment frames, p. 14

- 4.1—Types of concrete moment frames
- 4.2—Reinforced concrete beam-column moment frames
- 4.3—Post-tensioned concrete beam-column moment frames
- 4.4—Slab-column moment frames

Chapter 5—Notation, definitions, and acronyms, p. 30

- 5.1—Notation
- 5.2—Definitions
- 5.3—Acronyms

Chapter 6—References, p. 33

- 6.1—Referenced standards and reports
- 6.2—Cited references

ACI 369R-11 was adopted and published February 2011.
Copyright © 2011, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

CHAPTER 1—INTRODUCTION AND SCOPE

1.1—Introduction

Earthquake reconnaissance has clearly demonstrated that existing concrete frame buildings designed before the introduction of modern seismic codes are more vulnerable to severe damage or collapse when subjected to strong ground motion. Seismic rehabilitation of existing buildings where new components are added or existing components are modified or retrofitted with new materials, or both, can be used to mitigate the risk to damage in future earthquakes. Seismic rehabilitation is encouraged not only to reduce the risk of damage and injury in future earthquakes, but also to extend the life of existing buildings and reduce using new materials in the promotion of sustainability objectives.

1.2—Scope

This guide describes methods for estimating the seismic performance of concrete components in an existing building. The guide is intended to be used with the analysis procedures and Rehabilitation Objectives (ROs) established in ASCE/SEI 41-06 for the Systematic Rehabilitation Method. The methods described apply to existing concrete components of a building system, rehabilitated concrete components of a building system, and new concrete components added to an existing building system. Provisions of this guide do not apply to concrete-encased steel composite components.

Chapter 2 recommends data collection procedures for obtaining material properties and performing condition assessments. Chapter 3 provides general analysis and design requirements for concrete components. Chapter 4 provides modeling procedures, component strengths, acceptance criteria, and rehabilitation measures for cast-in-place concrete moment frames.

C1.2—Scope

This guide has been developed to provide a document that can be easily updated to reflect results from ongoing research on the seismic performance of existing concrete buildings. ACI 369R closely follows the format of Chapter 6, “Concrete” of ASCE/SEI 41-06, to make it readily accessible to engineers and to facilitate updates. Although the content in this version is similar to Chapter 6 of ASCE/SEI 41-06, this will change with timely updates specific to ongoing research. The intent is to provide a continuously updated resource document for future modifications to Chapter 6 of ASCE/SEI 41-06, similar to how the National Earthquake Hazards Reduction Program (NEHRP) Recommended Provisions produced by the Federal Emergency Management Agency (FEMA) (FEMA 450) have served as source documents for the International Building Code (IBC) and its predecessor building codes.

The goal of developing a guide rather than a standard is to focus the updating effort on improving technical content over development of codified language. New research results reviewed by the committee can now be implemented more quickly, accelerating communication between researchers and engineers while providing design professionals with the latest recommendations for the seismic

assessment and rehabilitation of concrete buildings. For this version of the guide, most sections are similar to Chapter 6 of ASCE/SEI 41 Supplement 1 (ASCE/SEI Ad Hoc Committee 2007). The most recent version, however, does not provide modeling procedures, acceptance criteria, and rehabilitation measures for precast concrete frames, infill frames, braced frames, shear walls, diaphragms, and foundations. Future versions will provide provision updates for concrete moment frames and will add provisions for concrete components and systems omitted in the present version of the guide.

This guide should be used in conjunction with Chapters 1 through 4 of ASCE/SEI 41-06. Chapter 1 of ASCE/SEI 41-06 provides rehabilitation requirements, including description of ROs, Building Performance Levels, and seismic hazard. Chapter 2 of ASCE/SEI 41-06 provides general design requirements, including determination of as-built information, limitations for linear and nonlinear analysis procedures, definition of force- and deformation-controlled actions, procedures for construction quality assurance, and methods for determining alternative modeling parameters and acceptance criteria. Chapter 3 of ASCE/SEI 41-06 provides a detailed description of all linear and nonlinear analysis procedures referenced in ACI 369R. Chapter 4 of ASCE/SEI 41-06 provides geotechnical engineering provisions for building foundations and assessment of seismic-geologic site hazards. References to these chapters can be found throughout the guide. This guide provides short descriptions of potential seismic rehabilitation measures for each concrete building system. The design professional, however, is referred to the FEMA report, FEMA 547, for detailed information on seismic rehabilitation measures for concrete buildings. Repair techniques for earthquake-damaged concrete components are not included in ACI 369R. The design professional is referred to FEMA 306, FEMA 307, and FEMA 308 for information on evaluation and repair of damaged concrete wall components.

Concrete-encased steel composite components frequently behave as over-reinforced sections. This type of component behavior was not represented in the data sets used to develop the force-deformation modeling relationships and acceptance criteria in this guide. Concrete encasement is often provided for fire protection rather than for strength or stiffness, and typically lacks transverse reinforcement. In some cases, the transverse reinforcement does not meet detailing requirements in the American National Standards Institute (ANSI)/American Institute of Steel Construction (AISC) Code (ANSI/AISC 360). Lack of adequate confinement may result in expansion of the core concrete, which exacerbate bond slip and, consequently, undermines the fundamental principle that plane sections remain plane.

Testing and analysis used to determine acceptance criteria for concrete-encased steel composite components should include the effect of bond slip between steel and concrete, confinement ratio, confinement reinforcement detailing kinematics, and appropriate strain limits.