Chile Earthquake of 2010

Assessment of Industrial Facilities around Concepción



J.G. (Greg) Soules, P.E., S.E. Rohert F Rachman PF SF



This is a preview. Click here to purchase the full publication.

Chile Earthquake of 2010

Assessment of Industrial Facilities around Concepción

J. G. (Greg) Soules, P.E., S.E. Robert E. Bachman, P.E., S.E. John F. Silva, P.E., S.E.





Published by the American Society of Civil Engineers

This is a preview. Click here to purchase the full publication.

Library of Congress Cataloging-in-Publication Data

Names: Soules, J. G. (J. Greg), author. | Bachman, Robert E., author. | Silva, John F., author. Title: Chile earthquake of 2010 : assessment of industrial facilities around Concepciâon / J.G. (Greg) Soules, P.E., S.E., Robert E. Bachman, P.E., S.E., John F. Silva, S.E. Description: Reston, Virginia : American Society of Civil Engineers, [2016] Includes bibliographical references and index. Identifiers: LCCN 2015048082 (print) | LCCN 2015051462 (ebook) | ISBN 9780784413647 (print) | ISBN 9780784478592 (pdf) Subjects: LCSH: Industrial buildings--Earthquake effects--Chile--Concepciâon Region. | Earthquake hazard analysis--Chile--Concepciâon Region. | Chile Earthquake, Chile, 2010 (February 27) | Earthquake resistant design--Standards--Chile. Classification: LCC TA654.6 .S652 2016 (print) | LCC TA654.6 (ebook) | DDC 624.1/762098339--dc23 LC record available at http://lccn.loc.gov/2015048082

Published by American Society of Civil Engineers 1801 Alexander Bell Drive Reston, Virginia 20191-4382 www.asce.org/bookstore | ascelibrary.org

Any statements expressed in these materials are those of the individual authors and do not necessarily represent the views of ASCE, which takes no responsibility for any statement made herein. No reference made in this publication to any specific method, product, process, or service constitutes or implies an endorsement, recommendation, or warranty thereof by ASCE. The materials are for general information only and do not represent a standard of ASCE, nor are they intended as a reference in purchase specifications, contracts, regulations, statutes, or any other legal document. ASCE makes no representation or warranty of any kind, whether express or implied, concerning the accuracy, completeness, suitability, or utility of any information, apparatus, product, or process discussed in this publication, and assumes no liability therefor. The information contained in these materials should not be used without first securing competent advice with respect to its suitability for any general or specific application. Anyone utilizing such information assumes all liability arising from such use, including but not limited to infringement of any patent or patents.

ASCE and American Society of Civil Engineers-Registered in U.S. Patent and Trademark Office.

Photocopies and permissions. Permission to photocopy or reproduce material from ASCE publications can be requested by sending an e-mail to permissions@asce.org or by locating a title in ASCE's Civil Engineering Database (http://cedb.asce.org) or ASCE Library (http://ascelibrary.org) and using the "Permissions" link.

Errata: Errata, if any, can be found at http://dx.doi.org/10.1061/978078441364.

Copyright © 2016 by the American Society of Civil Engineers. All Rights Reserved. ISBN 978-0-7844-1364-7 (print) ISBN 978-0-7844-7859-2 (PDF) Manufactured in the United States of America.

22 21 20 19 18 17 16 1 2 3 4 5

Table of Contents

Contributor	s and Acknowledgments	V
Chapter 1:	Introduction	1
Chapter 2:	Ground Motion Records	3
Chapter 3:	Assessment of CAP Acero Steel Plant	7
	Coke Plant Assessment	9
	Coal Bin Adjacent to Blast Furnaces	
	Steel Shop	12
	Hot Rolling Mill	
	Bar Mill (New)	
	Water Treatment Plant	
	Pier	
	General Conclusions and Recommendations	22
Chapter 4:	Assessment of ENAP Bio Bio Refinery	
	Tank Farm Assessment	
	Coker Unit	
	Cooling Tower	38
	Process Units (Hydrocracking, Isomerization, and Catalytic Cracking Units, Ethylene Plant)	40
	HDT Unit Pipe Rack and Supported Fin Fan	
	Consequential Damage Caused by Piping Inertial Forces and Relative	
	Displacements	45
	General Conclusions and Recommendations	
Chapter 5:	Assessment of Abastible San Vicente Liquefied Petroleum Gas	
Chapter 5.	(LPG) Terminal	49
	LPG Spheres Assessment	
	LPG Tank Assessment	
	Pipe Rack Assessment	
	Wall Assessment	58
	Control Room Assessment	
	Electrical Room and Mechanical Room Assessments	59
	Pump Room Assessments	61
	Pier Assessment	
	General Conclusions and Recommendations	65
Chapter 6:	Assessment of Santa Maria Power Station	67
	Boiler Structure Assessment and Observations	
	Coal Bins Assessment	68
	Coal Pile Conveyor and Support Structure Assessment and Observations	68
	Conveyor Tunnel Assessment	
	Stack Assessment and Observations	
	Tank Assessment and Observations	74

	Removable Anchor Bolts Assessment	75
	Miscellaneous Connections Assessment and Observations	75
	General Conclusions and Recommendations	78
Chapter 7:	Assessment of Base Isolated Pier	79
	Base Isolators Assessment and Observations	79
	Isolation Joint Assessment and Observations	80
	Crane Assessment and Observations	
	General Conclusions and Recommendations	82
Chapter 8:	Anchor Bolt Performance	
	Anchor Bolt Behavior-Stacks and Vessels	83
	Anchor Bolt Behavior—Column Baseplates	86
	Anchor Bolt Behavior—Pedestals and Saddles	93
Chapter 9:	Industrial Assessment Team Recommendations	99
(Appendixes	
(The app	endixes are available for download at <u>http://dx.doi.org/10.1061/9780784413647</u> .)
Appendix A	Chilean Standard NCh433.Of96: Seismic Design of Buildings	
Appendix B	Chilean Standard NCh2369.Of2003: Earthquake-Resistant Design of Industrial Structures and Facilities	
Appendix C	Drawings for Coal Bin, Coal Hopper, Holding Basins, and Pier Structure, CAP Acero Steel Plant	
Appendix D	ENAP Engineering Standard EI-001: Structural Steel Design and Fabrication	
Appendix E	ENAP Engineering Standard EI-002: Foundations and Elevated Structures	
Appendix F	ENAP Engineering Standard EI-004: Wind, Earthquake, and Snow Loading	
Appendix G	ENAP Engineering Standard EI-005e: Anchor Bolts	
Appendix H	Soil Report for Hydrocracking Unit, ENAP Bio Bio Refinery	
Appendix I	Drawings for LPG Spheres and LPG Tank, Abastible San Vicente LPG Terminal	
Index		.101

Contributors and Acknowledgments

The Structural Engineering Institute (SEI) of ASCE and the individual team members would like to acknowledge the efforts and participation of many individuals, organizations, and agencies that made this report possible. Support received by the team allowed a rapid reconnaissance effort to obtain and evaluate perishable data. Below are listed those who were instrumental in the success of the overall efforts of the team. In addition, the special efforts of individuals are recognized in the individual site visit sections.

The team is indebted to our employers for their support and contribution of time and, in several cases, travel finances. SEI and ASCE staffs were very helpful in gaining the approval from the ASCE Board of Directors for funding this trip. SEI staff was also very helpful in making arrangements and organizing logistics. Additionally, the team would like to thank Brendan Doherty and Veronica Montenegro Varas for their critical help in local contacts and arrangements.

The team would also like to acknowledge the support of Jim Rossberg of SEI throughout the preparation of the trip, reporting of these observations and arranging for publication at ASCE.

ASCE/SEI Chile Assessment Team

John D. Hooper, P.E., S.E., Team Leader, of MKA, Seattle, WA

Robert E. Bachman, S.E., R.E. Bachman Consulting, Los Angeles, CA David Bonneville, P.E., S.E., Degenkolb Engineers, San Francisco, CA Sergio Breña, University of Massachusetts, Amherst, MA J. Dan Dolan, Ph.D., P.E., Washington State University, Pullman, WA Ramon Gilsanz, P.E., S.E., Gilsanz Murray & Steficek LLP, New York, NY Ronald O. Hamburger, P.E., S.E., Simpson Gumpertz & Heger, San Francisco, CA James Harris, Ph.D., P.E., S.E., J.R. Harris & Associates, Denver, CO Jay Harris, Ph.D., P.E., National Institute of Standards and Technology, Gaithersburg, MD John Heintz, S.E., Applied Technology Council, Redwood City, CA Martin Johnson, ABS Consulting, Los Angeles, CA Dominic Kelly, Simpson Gumpertz & Heger, Cambridge, MA Robert Pekelnicky, P.E., S.E., Degenkolb Engineers, San Francisco, CA Steve Pryor, P.E., Simpson Strong-Tie, Seattle, WA Douglas Rammer, P.E., U.S. Forest Products Laboratory, Madison, WI James A. Rossberg, P.E., American Society of Civil Engineers, Reston, VA John F. Silva, P.E., S.E., Hilti Corporation, San Francisco, CA J. G. (Greg) Soules, P.E., S.E., Chicago Bridge & Iron Company, Houston, TX John Tawresey, P.E., S.E., KPFF Consulting Engineers, Seattle, WA John Van de Lindt, Ph.D., Colorado State University, Fort Collins, CO

Acknowledgments

The investigation of the industrial facilities described in this report was made possible by several institutions and individuals:

Marcel Carpo and Jaime Inzunza, Abastible LPG terminal

Sebastian Otero Gleisner, CAP Acero Steel Plant (Huachipato, Chile)

Fernando Raiqueo Vaccaro, ENAP Bio Bio Refinery

Hugo A. Briones, Santa Maria Power Plant

Carlos Aguirre, University of Santa Maria

Arturo Millan, University of Santa Maria (guide)

Ernesto Cruz, Catholic University

In particular, the engineering staffs at CAP Acero and at ENAP were generous with their time and resources.

The Industrial Assessment Team is indebted to Hilti and to Chicago Bridge and Iron for the support of two of the team members.

Chapter 1 Introduction

On February 27, 2010 a magnitude (Mw) 8.8 earthquake struck off the coast of South-Central Chile (Maule, see Figure 1-1). It was the largest ground motion event in Chile since the magnitude 9.5 earthquake of 1960 and is listed by USGS as the fifth largest tectonic event ever recorded (as of February 27, 2010). The Structural Engineering Institute (SEI) of the American Society of Civil Engineers (ASCE) began planning for a reconnaissance mission to the affected zone with the intent of gathering information useful to code development. Several teams were formed, each consisting of three or more members tasked with a particular structure type or design issue.

This report, originally compiled in 2010, documents the finding of the Industrial Assessment Team, and was intended to inform code development activities connected with earthquake protection measures for industrial facilities. Accordingly, the inquiries of the Industrial Assessment Team were concentrated on identifying strengths and weaknesses in the response of industrial structures to the seismic event. It was anticipated that damage to industrial facilities had occurred, but that industrial structures designed to newer codes and standards would perform better than those designed to older codes and standards. Chile is unique in that it has a separate standard for industrial structures, NCh2369.Of 2003: Earthquake-Resistant Design of Industrial Structures and Facilities. Requirements in NCh2369 are similar to those found in the 1994 UBC for nonbuilding structures. Because of the similarity between US and Chilean standards, understanding how heavy industrial facilities performed in this seismic event is vitally important to US design practice because the design practice for nonbuilding structures has varied significantly from that employed for building structures since the publication of the 1988 UBC. Observations of the performance of industrial facilities in this seismic event provides a window to how heavy industrial facilities may perform in the next large seismic event in the western US and where US heavy industrial facilities should focus their retrofit efforts.




Figure 1-1: Locations of ground motion stations and of sites visited in the Concepción area (Source: GeoEye).

Chapter 2 Ground Motion Records

There are only two ground motion records for the Concepción area and no ground motion records that are particularly close to Coronel (see Figure 1-1). Figure 2-1 shows a close-up of the locations of the two ground motion records and the three facilities located near Concepción. While no ground motion records exist for the facilities visited by the Industrial Assessment Team, the two ground motion records noted above are representative of the ground motions experienced in this region. The actual ground motions experienced at the facilities visited may be different.



Figure 2-1: Detail of location of ground motion instruments and visited facilities in Concepción (Source: GeoEye).

The preliminarily determined response spectra, shown in Figure 2-2, were determined from data taken from a ground motion instrument located at a school near the intersection of San Martin and Anibal Pinto, 100 meters south from the main square in Concepción. The soil was identified as Site Class C as defined in ASCE/SEI 7-05. The preliminarily determined response spectra, shown in Figure 2-3, were determined from data taken from a ground motion instrument located at the Concepción Colegio San Pedro. The soil for this record was not identified. The preliminarily