

DIN EN 1745



ICS 91.080.30; 91.120.10

Supersedes
DIN EN 1745:2012-07

**Masonry and masonry products –
Methods for determining thermal properties;
English version EN 1745:2020,
English translation of DIN EN 1745:2020-10**

Mauerwerk und Mauerwerksprodukte –
Verfahren zur Bestimmung von wärmeschutztechnischen Eigenschaften;
Englische Fassung EN 1745:2020,
Englische Übersetzung von DIN EN 1745:2020-10

Maçonnerie et éléments de maçonnerie –
Méthodes pour la détermination des propriétés thermiques;
Version anglaise EN 1745:2020,
Traduction anglaise de DIN EN 1745:2020-10

Document comprises 96 pages

Translation by DIN-Sprachendienst.

In case of doubt, the German-language original shall be considered authoritative.

A comma is used as the decimal marker.

National foreword

This document (EN 1745:2020) has been prepared by Technical Committee CEN/TC 125 “Masonry” (Secretariat: BSI, United Kingdom).

The responsible German body involved in its preparation was *DIN-Normenausschuss Bauwesen* (DIN Standards Committee Building and Civil Engineering), Working Committee NA 005-06-01 AA “Masonry structures (national mirror committee for CEN/TC 125, CEN/TC 125/WG 7, CEN/TC 125/WG 8, CEN/TC 250/SC 6 and ISO/TC 179)”.

For current information on this document, please go to DIN’s website (www.din.de) and search for the document number in question.

Amendments

This standard differs from DIN EN 1745:2012-07 as follows:

- a) Figure 1 has been replaced by Table 1 a and Table 1 b;
- b) editorial improvements have been made;
- c) definitions 3.1.5 and 3.1.10 have been changed;
- d) a term has been corrected in Annex A;
- e) a column heading has been amended in Annex A;
- f) Annex G has been added.

Previous editions

DIN EN 1745: 2002-08, 2012-07

English Version

Masonry and masonry products - Methods for determining thermal properties

Maçonnerie et éléments de maçonnerie -
Méthodes pour la détermination des propriétés thermiques

Mauerwerk und Mauerwerksprodukte -
Verfahren zur Bestimmung von wärmeschutztechnischen
Eigenschaften

This European Standard was approved by CEN on 17 May 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	4
Introduction	5
1 Scope	8
2 Normative references	8
3 Terms, definitions and symbols.....	9
3.1 Terms and definitions	9
3.2 Symbols.....	10
4 Determination of $\lambda_{10,dry,unit}$ -values for solid masonry units and $\lambda_{10,dry,mor}$ -values for mortars	11
4.1 General.....	11
4.2 $\lambda_{10,dry,mat}$ -values for solid masonry units and mortars.....	12
4.2.1 Method S1. Determination of $\lambda_{10,dry,unit}$ -values from tabulated $\lambda_{10,dry,mat}$ /net dry density relationship	12
4.2.2 Method S2. Determination of $\lambda_{10,dry,unit}$ -values based on $\lambda_{10,dry,mat}$ /net dry density curve	12
4.2.3 Method S3. Determination of $\lambda_{10,dry,unit}$ -values from determining the thermal transmittance (U_{mas}) of masonry built from solid masonry units and mortar	14
4.3 Test methods and numbers of samples to be taken	16
5 Determination of equivalent $\lambda_{10,dry,unit}$ -values for masonry units with formed voids and composite masonry units	16
5.1 General.....	16
5.2 Calculation methods.....	17
5.3 $\lambda_{10,dry,unit}$ -values of masonry units with formed voids and composite units	17
5.3.1 Determination of $\lambda_{10,dry,unit}$ -values from tabulated $\lambda_{unit} / \lambda_{mat}$ relationship	17
5.3.2 Determination of $\lambda_{10,dry,unit}$ -values based on calculation.....	18
5.3.3 Method P5. Determination of $\lambda_{10,dry,unit}$ -values from determining the thermal transmittance (U_{mas}) of masonry built from masonry units with formed voids or composite masonry units and mortar	18
5.4 Test methods and numbers of samples to be taken	21
6 Moisture conversion	22
6.1 General.....	22
6.2 Procedure A (for materials, mortar, solid masonry units and masonry):.....	22
6.3 Procedure B (for masonry units with formed voids):.....	23
6.4 Procedure C (for composite masonry units):.....	23
7 Determination of design thermal values ($R_{design,mas}$ or $\lambda_{design,mas}$) for masonry built from masonry units and mortar	23
7.1 General.....	23
7.2 $R_{design,mas}$ - or $\lambda_{design,mas}$ -values based on calculation.....	24
7.2.1 $R_{design,mas}$ - or $\lambda_{design,mas}$ -values based on λ_{design} -values for the masonry units and the mortar.....	24
7.2.2 $R_{design,mas}$ -or $\lambda_{design,mas}$ -values using a numerical calculation method based on the design thermal conductivity of the materials used -	24
7.3 $R_{design,mas}$ - or $\lambda_{design,mas}$ -values of masonry built from masonry units with formed voids and mortar based on tabulated values.....	24
7.3.1 Tabulated values	24
7.3.2 Application of Annex B.....	25
7.3.3 Alternative application of Annex B.....	25

7.4	Method S4/P6 $R_{design,mas}$ – or $\lambda_{design,mas}$ –values of masonry based on masonry testing	26
8	Determination of the thermal transmittance of masonry	26
9	Specific heat capacity	27
10	Rounding rules for λ-values for masonry units and masonry	27
Annex A	(normative) Tabulated $\lambda_{10,dry,mat}$ -values of materials used for masonry products	28
Annex B	(informative) $R_{dry,mas}$ - or $\lambda_{10,dry,mas}$ -values of masonry built from a range of masonry units containing formed voids.....	38
Annex C	(informative) Example of how to use the tables in Annex B	78
Annex D	(normative) Requirements for appropriate calculation procedures	80
D.1	Capabilities of the program	80
D.2	Input data and results.....	80
D.3	Testing of the program accuracy.....	81
D.4	Reference cases	81
D.4.1	Case 1: Calculation of thermal resistance R and thermal conductivity $\lambda_{10,dry,unit}$ of a masonry unit (vertically perforated unit)	81
D.4.2	Case 2: Calculation of thermal resistance $R_{dry,mas}$ of masonry consisting of vertically perforated masonry units, bed joints with mortar layers and internal/external plaster layers.....	83
D.4.3	CASE 3: Calculation of thermal resistance R_t of masonry consisting of masonry units, horizontal mortar layers, vertical mortar pockets and additional external insulation layer	85
Annex E	(informative) Assessment and verification of constancy of performance	89
Annex F	(informative) Alternative procedure for the moisture correction of units with formed voids.....	91
Annex G	(informative) Simplified methodology for determining design moisture content of composite masonry units.....	92

European foreword

This document (EN 1745:2020) has been prepared by Technical Committee CEN/TC 125 “Masonry”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2021, and conflicting national standards shall be withdrawn at the latest by January 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1745:2012.

The following is a list of significant technical changes since the last edition EN 1745:2012:

- replacement of Figure 1 by Tables 1 a and 1 b;
- editorial improvement;
- changes in the definitions 3.1.5 and 3.1.10;
- correction of term in Annex A;
- amendment heading of column in Annex A;
- addition of Annex G.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This document provides methods for the determination of dry and design thermal conductivity and thermal resistance values of masonry products and masonry.

The following types of masonry unit are covered by this document:

- solid masonry units;
- masonry units with formed voids;
- composite masonry units.

Methods are described for the determination of the dry thermal conductivity of solid masonry units ($\lambda_{10,dry,unit}$) and of mortar ($\lambda_{10,dry,mor}$) and for the determination of equivalent dry thermal conductivity of masonry units with formed voids and composite masonry units ($\lambda_{10,dry,unit}$). Procedures are also described for the determination of the design thermal values of masonry units and masonry. The different methods are illustrated in Table 1.

The value in dry state is a characteristic of a masonry material, masonry unit or of masonry.

The determination of thermal values can be based on tabulated data, measurements, calculations or a combination of these.

Design thermal values may be determined according to procedures given in this European standard according to the intended application, environmental and climatic conditions, bearing in mind the purpose of this determination, such as:

- energy consumption;
- design of heating and cooling equipment;
- surface temperature determination;
- compliance with national building regulations;
- consideration of non-steady-state thermal conditions in buildings.

Table 1 a — Determination of thermal properties of masonry units and masonry

Overview of methods to determine $\lambda_{10,dry,unit}$			
Method (Clause)	Masonry units	Determination of $\lambda_{10,dry,unit}$ ^{a b}	Required parameters
S1 (4.2.1)	solid	using tabulated value from Annex A for the $\lambda_{10,dry,mat}$ / net dry density relationship	Net dry density of unit/material ^a
S2 (4.2.2)	solid	based on determination of dry thermal conductivity by measurement and of the masonry unit material / dry density curve	Net dry density and thermal conductivity of unit/material ^a
S3 (4.2.3)	solid	based on determination of the thermal transmittance (U_{mas}) of masonry, then adjusting for the influence of the mortar	Net dry density and percentage area of units; thermal conductivity and percentage area of mortar
P1 (5.3.1.3)	with formed voids	based on determination of dry thermal conductivity of the masonry unit material, then using Annex B	Net dry density and thermal conductivity of unit/material and configuration of the units
P2 (5.3.1.4)	with formed voids	using tabulated values from Annex A, then using Annex B	Net dry density of unit/material and configuration of the units
P3 (5.3.2.2)	with formed voids and composite	by calculation according to 5.2, using dry thermal conductivity by measurement of the masonry unit material and any infill	Net dry density and thermal conductivity of unit/infill material and configuration of the units
P4 (5.3.2.3)	with formed voids and composite	by calculation according to 5.2 using tabulated thermal conductivity of the masonry unit material from Annex A and thermal conductivity of any infill material	Net dry density and thermal conductivity of unit/infill material and configuration of the units
P5 (5.3.3)	with formed voids and composite	based on determination of the thermal transmittance (U_{mas}) of masonry, then adjusting for the influence of the mortar	Gross dry density and percentage area of units, thermal conductivity and percentage area of mortar
^a Methods S1 and S2 are also applicable for the determination of $\lambda_{10,dry,mor}$. ^b If necessary, moisture correction according to Clause 6.			

Table 1 b — Determination of thermal properties of masonry units and masonry

Overview of methods to determine $\lambda_{design,unit}^a$ and $\lambda_{design,mas}^b$			
$\lambda_{design}^{a,b}$ (Clause)	Masonry units	Determination of $\lambda_{design,unit}^a$ / $\lambda_{design,mas}^b$	Required parameters
$\lambda_{design,unit}$ (6)	solid, with formed voids and composite	by applying moisture correction according to Clause 6 upon $\lambda_{10,dry,unit}$	Thermal conductivity in dry state and moisture conversion factor of unit
$\lambda_{design,mas}$ (7.2.1)	solid, with formed voids and composite	by using a simplified calculation based on $\lambda_{design,unit}$ and $\lambda_{design,mor}$	Design thermal conductivity of unit and mortar and percentage area of mortar joints
$\lambda_{design,mas}$ (7.2.2)	solid, with formed voids and composite	by numerical calculation based on $\lambda_{design,mat}$	Design thermal conductivity of materials and configuration
$\lambda_{design,mas}$ (7.3)	with formed voids	using of Annex B and application of the correction according to 6.3	Net dry density and thermal conductivity of unit/material and respective moisture conversion factors
S4/P6 $\lambda_{design,mas}$ (7.4)	solid, with formed voids and composite	by applying moisture correction according to Clause 6 onto the thermal transmittance (U_{mas}) of masonry	Thermal transmission of masonry and moisture conversion factor
^a Or alternatively the design thermal resistance of the unit $R_{design,unit}$. ^b Or alternatively the design thermal resistance of the masonry $R_{design,mas}$.			

1 Scope

This document specifies methods for the determination of thermal properties of masonry and masonry products.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 772-3, *Methods of test for masonry units — Part 3: Determination of net volume and percentage of voids of clay masonry units by hydrostatic weighing*

EN 772-4, *Methods of test for masonry units — Part 4: Determination of real and bulk density and of total and open porosity for natural stone masonry units*

EN 772-13, *Methods of test for masonry units — Part 13: Determination of net and gross dry density of masonry units (except for natural stone)*

EN 772-16, *Methods of test for masonry units — Part 16: Determination of dimensions*

EN 1015-10, *Methods of test for mortar for masonry — Part 10: Determination of dry bulk density of hardened mortar*

EN 1934, *Thermal performance of buildings — Determination of thermal resistance by hot box method using heat flow meter — Masonry*

EN 1936, *Natural stone test methods — Determination of real density and apparent density, and of total and open porosity*

EN 12664, *Thermal performances of building materials and products — Determination of thermal resistance by means of guarded hot plate and heat flow meter methods — Dry and moist products of medium and low thermal resistance*

EN 12667, *Thermal performance of building materials and products- Determination of thermal resistance by means of guarded hot plate and heat flow meter methods – Products of high and medium thermal resistance*

EN ISO 6946, *Building components and building elements — Thermal resistance and thermal transmittance — Calculation methods (ISO 6946)*

EN ISO 7345, *Thermal performance of buildings and building components — Physical quantities and definitions (ISO 7345)*

EN ISO 10211, *Thermal bridges in building construction — Heat flows and surface temperatures — Detailed calculations (ISO 10211)*