

DIN EN 1634-1



ICS 13.220.50; 91.060.50

Supersedes
DIN EN 1634-1:2014-03

**Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware –
Part 1: Fire resistance test for door and shutter assemblies and openable windows;
English version EN 1634-1:2014+A1:2018,
English translation of DIN EN 1634-1:2018-04**

Feuerwiderstandsprüfungen und Rauchschutzprüfungen für Türen, Tore, Abschlüsse, Fenster und Baubeschläge –

Teil 1: Feuerwiderstandsprüfungen für Türen, Tore, Abschlüsse und Fenster;

Englische Fassung EN 1634-1:2014+A1:2018,

Englische Übersetzung von DIN EN 1634-1:2018-04

Essais de résistance au feu et d'étanchéité aux fumées des portes, fermetures, fenêtres et éléments de quincailleries –

Partie 1: Essais de résistance au feu des portes, fermetures et fenêtres;

Version anglaise EN 1634-1:2014+A1:2018,

Traduction anglaise de DIN EN 1634-1:2018-04

Document comprises 78 pages

Translation by DIN-Sprachendienst.

In case of doubt, the German-language original shall be considered authoritative.

A comma is used as the decimal marker.

National foreword

This document (EN 1634-1:2014+A1:2018) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings” (Secretariat: BSI, United Kingdom).

The responsible German body involved in its preparation was *DIN-Normenausschuss Bauwesen* (DIN Standards Committee Building and Civil Engineering), Working Committee NA 005-52-05 AA “Reaction to fire of building materials and building components – Fire and smoke control door and shutter assemblies (national mirror committee for CEN/TC 127/WG 3 and sub-sections of ISO/TC 92/SC 2)”.

This standard includes Amendment A1 approved by CEN on 2017-09-25.

Amendments

This standard differs from DIN EN 1634-1:2014-03 as follows:

- a) the European foreword has been amended;
- b) the Scope has been amended;
- c) Clause 2 has been amended;
- d) Clause 3 has been amended;
- e) Clause 5 has been amended;
- f) Clause 6 has been amended;
- g) Clause 8 has been amended;
- h) Clause 9 has been amended;
- i) Table 2 has been modified;
- j) Figures 11, 12, 16, 24 and 33 have been revised;
- k) Annex B has been modified;
- l) the Bibliography has been amended.

Previous editions

DIN 4102-3: 1934-08, 1940-11, 1970-02

DIN 4102-5: 1977-09

DIN EN 1634-1: 2000-03, 2009-01, 2014-03

English Version

Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 1: Fire resistance test for door and shutter assemblies and openable windows

Essais de résistance au feu et d'étanchéité aux fumées des portes, fermetures, fenêtres et éléments de quincailleries - Partie 1: Essais de résistance au feu des portes, fermetures et fenêtres

Feuerwiderstandsprüfungen und Rauchschutzprüfungen für Türen, Tore, Abschlüsse, Fenster und Baubeschläge - Teil 1: Feuerwiderstandsprüfungen für Türen, Tore, Abschlüsse und Fenster

This European Standard was approved by CEN on 29 December 2012 and includes Amendment 1 approved by CEN on 25 September 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Test equipment	9
5 Test conditions.....	9
6 Test specimen.....	9
6.1 General.....	9
6.2 Size.....	9
6.3 Number	9
6.4 Design	9
6.5 Construction.....	10
6.6 Verification	10
6.7 Building hardware	10
7 Installation of test specimen	10
7.1 General.....	10
7.2 Supporting construction.....	11
7.3 Gaps.....	12
8 Conditioning.....	12
8.1 Moisture content	12
8.2 Mechanical	12
9 Application of instrumentation	12
9.1 Thermocouples	12
9.2 Pressure.....	18
9.3 Deflection.....	18
9.4 Radiation.....	18
10 Test procedure	19
10.1 Pre-test examination and preparation.....	19
10.2 Fire resistance test	20
11 Performance criteria	20
11.1 Integrity	20
11.2 Insulation	20
11.3 Radiation.....	21
12 Test report.....	21
13 Field of direct application of test results	22
13.1 General.....	22
13.2 Materials and construction.....	22
13.3 Permissible size variations.....	24
13.4 Asymmetrical assemblies.....	28

13.5	Supporting constructions	29
13.6	Associated supporting constructions	30
Annex A (normative) Conditioning requirements		66
A.1	General	66
A.2	Requirements	66
Annex B (normative) Field of direct application limits of permitted size variations		68
Annex C (informative) Background to field of direct application statements for asymmetric constructions and supporting constructions		70
C.1	General	70
C.2	Hinged doorsets	70
C.3	Pivot hung doorsets	73
C.4	Rolling shutter doorsets	74
C.5	Sliding/folding doorsets	75
Bibliography		76

European foreword

This document (EN 1634-1:2014+A1:2018) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This document includes Amendment 1 approved by CEN on 25 September 2017.

This document supersedes A1 EN 1634-1:2014 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2018, and conflicting national standards shall be withdrawn at the latest by July 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

EN 1634, "Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware" consists of the following parts:

- *Part 1: Fire resistance test for door and shutter assemblies and openable windows* (the present document);
- *Part 2: Fire resistance characterisation test for elements of building hardware;*
- *Part 3: Smoke control test for door and shutter assemblies.*

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

Caution

The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

It is imperative that an assessment of all potential hazards and risks to health is made and that safety precautions are identified and provided. Written safety instructions need to be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

1 Scope

This European Standard specifies a method for determining the fire resistance of door and shutter assemblies and openable windows designed for installation within openings incorporated in vertical separating elements, such as:

- a) hinged and pivoted doors;
- b) horizontally sliding and vertically sliding doors including articulated sliding doors and sectional doors;
- c) folding doors, sliding folding doors /shutters;
- d) tilting doors;
- e) rolling shutter doors;
- f) openable windows;
- g) operable fabric curtains.

This European Standard is used in conjunction with EN 1363-1.

The testing of fire dampers is covered by EN 1366-2.

The testing of closures for conveyor systems is covered by EN 1366-7.

By prior agreement with the test sponsor, additional information may be gained for individual elements of building hardware in order to fulfil the performance criteria identified in EN 1634-2. Based on the observations recorded during the test, the results may be presented in a separate report which should be in accordance with the requirements of EN 1634-2.

⌈A1⌋ Doors tested in accordance with this European Standard and classified in accordance with EN 13501-2 may be accepted for lift landing door applications as an alternative to EN 81-58 and subject to National Regulations. EN 81-58 represents a specific test for lift landing doors and results in an alternative classification which may not be suitable for some other purposes as defined in National Regulations. ⌋A1⌋

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

⌈A1⌋ EN 1363-1 ⌋A1⌋, *Fire resistance tests - Part 1: General Requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

⌈A1⌋ EN 12519 ⌋A1⌋, *Windows and pedestrian doors - Terminology*

EN 13501-2, *Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services*

⌈A1⌋ *deleted reference* ⌋A1⌋